

Agency Information

This certificate is only used for web browsing, proving that the SETsafe | SETfuse product has been certified.

For the full version, please contact: sales@SETfuse.com

Thank you for your support.

CERTIFICATE

No. B 107221 0010 Rev. 00

Model(s): LFR01-xxA10-yy, LFR01-xxxA10-yy,
LFR01-450A08-yy

xx=50, 63, 80 and

xxx=100, 125, 160, 200, 250, 315, 350, 400

denotes rated current 50A, 63A, 80A, 100A, 125A,
160A, 200A, 250A, 315A, 350A, 400A respectively.

yy=BB, FB, BT, FE denotes different terminal type

BB: Bolt blade terminal

FB: Flat bolt terminal

BT: Bolt tag terminal

FE: Flush end terminal

Parameters:

Model:	LFR01-xxA10-yy, LFR01-xxxA10-yy	LFR01-450A08-yy
Rated voltage:	DC1000V	DC800V
Rated current:	50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A	450A
Rated breaking capacity:	50kA	
Poles No.:	1-P	
Breaking range and utilization category:	aR	

Tested according to: EN 60269-1:2007/A2:2014
EN 60269-4:2009/A2:2016