

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Devices

Name and address of the applicant

Xiamen SET Electronics Co., Ltd.
No. 8087 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an,
361101 Xiamen, Fujian
China

Name and address of the manufacturer

Xiamen SET Electronics Co., Ltd.
No. 8087 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an,
361101 Xiamen, Fujian
China

Name and address of the factory

Note: When more than one factory, please report on page 2

Xiamen SET Electronics Co., Ltd.
No. 8087 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an,
361101 Xiamen, Fujian
China

☒ Additional Information on page 2

Ratings and principal characteristics

Test class I/Type 1 and Test class II / Type 2; Iscon: 6 kA; IP20;
Uic: 275 Vac, Iimp: 25 kA, In: 25 kA, Imax: 60 kA, Up:2,0 kV

Trademark / Brand (if any)

SET or SETfuse or SETsafe

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SD25B275D100, SD25B275D203, SD25B275D205, SD25B275D305,
SD25B275D404 and SD25B275D405

Additional Information (If necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6113730.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Amhem, 6525 MJ
Netherlands



Date: 2022-10-21

Signature: Kate Xu