

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！

Note: We are enhancing our systems and you may notice duplicate entries/missing/outdated data. During this interim period, please contact our Customer Service at <https://www.ul.com/about/locations>.


Special-purpose Fuses - Component

COMPANY

XIAMEN SET ELECTRONICS CO LTD

8067 XIANG'AN XI RD XIAMEN TORCH HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE, XIANG'AN INDUSTRY DIST
XIAMEN, Fujian 361101 China

E532248

Marking: Company name or trademark  ,  ,  ,  ,
 ,  ,  ,  , and model designation.

Note: For additional marking information, refer to the [Guide Information Page](#).

View model for additional information

Model(s): LFR000, f/b "-", f/b 50A, 63A, 80A, 100A, 125A, 150A, 160A, 200A or 250A, f/b 10, f/b -BT

Model(s): LFR15 followed by "-", followed by 32A, 40A, 50A, 63A, 80A or 100A, followed by 06, followed by "-", followed by BT.

Model(s): LFR15XL2 followed by "-", followed by 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 420A, 450A, followed by "-BB" or "-FB".

Model(s): LFR15XL3 followed by "-", followed by 400A, 450A, 500A, 550A, 630A, followed by "-BB" or "-FB".

Model(s): LFR20S , followed by -32A, -40A, -50A, -63A, -80A, -100A, -125A, -160A, -200A or -250A, followed by -BT.

Model(s): SHP, followed by -XX, followed by 30, 40, 45, 50, 60, 65 or 75. "XX" maybe any two numbers 00~99, represents customer code for commercial use.

Special purpose fuses, rating 30-60 A, voltage 125 Vdc or less, rating 70-125 A, voltage 100 Vdc or less, rating 150-200 A, voltage 75 Vdc or less., Model(s): SCF61011 , followed by 30, 40, 50, 60, 70, 80, 90, 100, 125, 150 or 200, followed by A, followed by X, followed by V. (XV)- Rated voltage code, Rated current is 30-60A, X maybe 125, 75 or 24. Rated current is 70-125A, X maybe 100, 75 or 24. Rated current is 150-200A, X maybe 75 or 24.

Special purpose fuses, ampere rating 800-2000 A, voltage rating 1500 Vdc or less, Model(s): LFR15XL4, followed by -, followed by 800A, 1000A, 1250A, 1500A, 1600A, 1800A or 2000A, followed by -FE

Special purpose fuses, ampere rating 800-2000 A, voltage rating 1500 Vdc or less, Model(s): LFR15XL5, followed by -, followed by 1800A, 2000A, 2200A, 2500A, 2800A or 3000A, followed by -FE

Last Updated on 2025-06-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."