

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！



Product Service

Attestation of Conformity

No. N8A 107221 0016 Rev. 00

Model(s):

- 1) Models LFR10-xxA04-yy, LFR10-xxA04-yyy:
 xx=32, 40, 50 denotes rated current
 32A, 40A, 50A respectively.
 yy=CF, BT and yyy=PT1, PT2 denotes different
 terminal types
 CF: Cylindrical ferrule terminal
 BT: Bolt tag terminal
 PT1: PCB mounting terminal
 PT2: PCB mounting terminal
- 2) Models LFR2836-xxxA05-yy:
 xxx=100, 125, 160, 200, 250, 315, 350, 400, 450,
 500, 550, 630 denotes rated current 100A,
 125A, 160A, 200A, 250A, 315A, 350A, 400A,
 450A, 500A, 550A, 630A respectively.
 yy=BT, BK denotes different terminal types
 BT: Bolt tag terminal
 BK: Blade knife terminal

Brand:

SET

Parameters:

Model:	LFR10-xxA04-yy, LFR10-xxA04-yyy	LFR2836-xxxA05-yy
Rated voltage:	AC 400V	DC 500V
Rated current:	32A, 40A, 50A	100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 450A, 500A, 550A, 630A
Rated breaking capacity:	50kA	
Poles No.:	1-P	
Breaking range and utilization category:	aR	

Tested according to:

EN 60269-1:2007/A2:2014
 EN 60269-4:2009/A2:2016

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.