

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！

CERTIFICATE

No. B 107221 0015 Rev. 00

Model(s):

- 1) Models LFR10-xxA04-yy, LFR10-xxA04-yyy:
 xx=32, 40, 50 denotes rated current
 32A, 40A, 50A respectively.
 yy=CF, BT and yyy=PT1, PT2 denotes different
 terminal types
 CF: Cylindrical ferrule terminal
 BT: Bolt tag terminal
 PT1: PCB mounting terminal
 PT2: PCB mounting terminal
- 2) Models LFR2836-xxxA05-yy:
 xxx=100, 125, 160, 200, 250, 315, 350, 400, 450,
 500, 550, 630 denotes rated current 100A,
 125A, 160A, 200A, 250A, 315A, 350A, 400A,
 450A, 500A, 550A, 630A respectively.
 yy=BT, BK denotes different terminal types
 BT: Bolt tag terminal
 BK: Blade knife terminal

Brand Name: SET

Parameters:

Model:	LFR10-xxA04-yy, LFR10-xxA04-yyy	LFR2836-xxxA05-yy
Rated voltage:	AC 400V	DC 500V
Rated current:	32A, 40A, 50A	100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 450A, 500A, 550A, 630A
Rated breaking capacity:	50kA	
Poles No.:	1-P	
Breaking range and utilization category:	aR	

Tested according to: EN 60269-1:2007/A2:2014
 EN 60269-4:2009/A2:2016